



Presented By

THE CITY OF
SAN FERNANDO

ANNUAL
**WATER
QUALITY
REPORT**

WATER TESTING PERFORMED IN 2017



Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Quality First

Once again we are pleased to present our annual water quality report. As in years past, we are committed to delivering the best-quality drinking water possible. To that end, we remain vigilant in meeting the challenges of new regulations, source water protection, water conservation, and community outreach and education, while continuing to serve the needs of all of our water users. Thank you for allowing us the opportunity to serve you and your family.

Community Participation

You are invited to participate at our City Council meetings and voice your concerns about your drinking water. The City Council meets every first and third Monday of each month, beginning at 6 p.m. at City Hall, 117 Macneil Street, San Fernando, CA.

Important Health Information

Nitrate in drinking water at levels above 45 ppm is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 45 ppm may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health-care provider.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>.

Where Does My Water Come From?

The City of San Fernando, incorporated in 1911, provides water service to an area of approximately 2.42 square miles with an approximate population of 24,560 residents. Annually, the city serves approximately 1 billion gallons of water to our customers. San Fernando residents are fortunate to have three sources of water: (1) local ground-water wells that draw water from the Sylmar basin; (2) imported water from the Metropolitan Water District (MWD), which delivers surface water from the Joseph Jensen Plant; and (3) a connection from the City of Los Angeles distribution system that is used only in extreme emergencies. In 2017, the City of San Fernando received 100 percent of its water supply from local ground water.

Substances That Could Be in Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (U.S. EPA) and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;

Inorganic Contaminants, such as salts and metals, that can be naturally occurring or can result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, that may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and which can also come from gas stations, urban storm-water runoff, agricultural applications, and septic systems;

Radioactive Contaminants, that can be naturally occurring or can be the result of oil and gas production and mining activities.

More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Source Water Assessment

In August 2002 the California Department of Public Health, Drinking Water Field Operations Branch, Central District, conducted a Drinking Water Source Assessment for the City of San Fernando Water Division. The purpose of the assessment was to determine the vulnerability of our water sources to “possible contaminating activities.” The following are the results for wells 2A, 3, 4A, and 7A.

SOURCE	VULNERABILITY ASSOCIATED WITH DETECTED CONTAMINANTS	VULNERABILITY NOT ASSOCIATED WITH ANY DETECTED CONTAMINANTS
Well 2A	Housing-high density; Parks; Septic systems-high density; Apartments and condominiums	Sewer collection systems
Well 3	Housing-high density; Parks; Septic systems-high density; apartments and condominiums	Sewer collection systems, Automobile gas stations, Dry cleaners
Well 4A	Sewer collection systems; Dry cleaners	None
Well 7A	Housing-high density; Septic systems-high density; Apartments and condominiums	Automobile gas stations

Count on Us

Delivering high-quality drinking water to our customers involves far more than just pushing water through pipes. Water treatment is a complex, time-consuming process. Because tap water is highly regulated by state and federal laws, water treatment plant and system operators must be licensed and are required to commit to long-term, on-the-job training before becoming fully qualified. Our licensed water professionals have a basic understanding of a wide range of subjects, including mathematics, biology, chemistry, and physics. Some of the tasks they complete on a regular basis include:

- Operating and maintaining equipment to purify and clarify water;
- Monitoring and inspecting machinery, meters, gauges, and operating conditions;
- Conducting tests and inspections on water and evaluating the results;
- Maintaining optimal water chemistry;
- Applying data to formulas that determine treatment requirements, flow levels, and concentration levels;
- Documenting and reporting test results and system operations to regulatory agencies; and
- Serving our community through customer support, education, and outreach.



Water treatment is a complex, time-consuming process.

How Is My Water Treated and Purified?

The treatment process consists of some basic steps. First, ground water is drawn from the Sylmar basin, then chlorine is injected in a sodium hypochlorite solution of 0.8% for disinfection (as a precaution against any bacteria that may be present). The city’s wells utilize an on-site chlorine generation (OSG) system, in which the 0.8% of sodium hypochlorite solution is used as a disinfectant agent. Through an electrolytic process, the OSG operates automatically, requiring only salt, water (softened), and electricity to produce the sodium hypochlorite solution. We carefully monitor on a daily basis the amount of chlorine injected at each well site. Water is then pumped to reservoirs, where it flows by gravity through the distribution system into your home or business. Likewise, chlorine residuals are monitored from the distribution system daily in order to ensure a reliable supply of drinking water.



QUESTIONS?

If you should have any questions relating to your drinking water, or for additional information regarding this report, you may contact Public Works Superintendent Tony Salazar at (818) 898-1294.

So, the next time you turn on your faucet, think of the skilled professionals who stand behind each drop.

How Long Can I Store Drinking Water?

The disinfectant in drinking water will eventually dissipate, even in a closed container. If that container housed bacteria prior to filling up with the tap water, the bacteria may continue to grow once the disinfectant has dissipated. Some experts believe that water could be stored up to six months before needing to be replaced. Refrigeration will help slow the bacterial growth.

Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. (If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.) If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/lead.

Water Conservation Tips

You can play a role in conserving water and saving yourself money in the process by becoming conscious of the amount of water your household is using and by looking for ways to use less whenever you can. It is not hard to conserve water. Here are a few tips:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So, get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank. Watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from an invisible toilet leak. Fix it and you can save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances. Then check the meter after 15 minutes. If it moved, you have a leak.



Test Results

Our water is monitored for many different kinds of substances on a very strict sampling schedule. The information in the data tables shows substances that were detected between January 1 and December 31, 2017. For additional information past substances that were detected have been included, ranging from 2009 to 2016. Remember that detecting a substance does not necessarily mean the water is unsafe to drink; our goal is to keep all detects below their respective maximum allowed levels.

The State recommends monitoring for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

REGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	PHG (MCLG) [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Chromium (ppb)	2017	50	(100)	3.5	3.2–3.8	No	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (ppm)	2017	2.0	1	0.31	0.22–0.37	No	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Free Chlorine Residual (ppm)	2017	[4.0]	NS	1.82	1.00–2.80	No	Drinking water disinfectant added for treatment
Haloacetic Acids (ppb)	2017	60	NA	0.5	ND–3.1	No	By-product of drinking water disinfection
Hexavalent Chromium¹ (ppb)	2017	NS	0.02	3.62	3.33–3.87	No	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits
Nitrate [as nitrate] (ppm)	2017	45	45	34	29–38	No	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate [as nitrogen] (ppm)	2017	10	10	7.7	6.6–8.6	No	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Perchlorate (ppb)	2017	6	1	2.2	2.0–2.4	No	An inorganic inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries; historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts
TTHMs [Total Trihalomethanes] (ppb)	2017	80	NA	8.7	2.2–26.0	No	By-product of drinking water disinfection
Tetrachloroethylene [PCE] (ppb)	2017	5	0.06	0.72	0.62–0.81	No	Discharge from factories, dry cleaners, and auto shops (metal degreaser)
Turbidity (NTU)	2017	TT	NA	0.05	ND–0.26	No	Soil runoff

Tap Water Samples Collected for Lead and Copper Analyses from Sample Sites throughout the Community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	PHG (MCLG)	AMOUNT DETECTED (90TH%TILE)	SITES ABOVE AL/TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2017	1.3	0.3	0.3	0/30	No	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (ppb)	2017	15	0.2	ND	0/30	No	Internal corrosion of household water plumbing systems; discharge from industrial manufacturers; erosion of natural deposits

SECONDARY SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	SMCL	PHG (MCLG)	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Odor-Threshold (TON)	2017	3	NS	1.45	ND–2.0	No	Naturally occurring organic materials

UNREGULATED AND OTHER SUBSTANCES ²

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Aggressiveness Index Corrosivity (Units)	2016	12	12–12	Elemental balance in water; affected by temperature, other factors
Alkalinity [Total] as CaCO₃ (ppm)	2016	180	180–180	Naturally occurring
Anion Sum-Calculated (Units)	2009	6.9	5.8–7.8	Naturally occurring
Bicarbonate [as HCO₃] (ppm)	2016	230	230–230	Naturally occurring
Boron (ppb)	2014	160	160–160	Runoff/leaching from natural deposits; industrial wastes
Calcium (ppm)	2016	69	69–69	Erosion; leaching of natural deposits
Carbon Dioxide (ppb)	2015	5,800	5,400–6,200	Naturally occurring
Cation Sum-Calculated (Units)	2009	6.2	2.5–7.0	Naturally occurring
Chlorate (ppb)	2015	133	130–140	By-product of drinking water chlorination; industrial processes
Chlorodifluoromethane (ppb)	2015	380	360–400	NA
Chloroform (ppb)	2017	0.57	0.52–0.61	By-product of drinking water disinfection
Hardness [Total] as CaCO₃ (ppm)	2015	230	200–260	Erosion; leaching of natural deposits
Langelier Index at 60 C	2016	1.0	1.0–1.0	NA
Magnesium (ppm)	2015	17	12–21	Erosion; leaching of natural deposits
Molybdenum (ppb)	2015	4	4–4	NA
pH (Units)	2016	7.8	7.8–7.8	Naturally occurring
Potassium (ppm)	2015	3.9	3.4–4.4	Erosion; leaching of natural deposits
Sodium (ppm)	2015	30	26–33	Erosion; leaching of natural deposits; sea water influence
Strontium (ppb)	2015	517	500–530	NA
Vanadium (ppb)	2015	7	7–8	Naturally occurring; industrial waste discharge

¹ There is currently no MCL for hexavalent chromium. The previous MCL of 10 ppb was withdrawn on September 11, 2017.

² Unregulated contaminant monitoring helps U.S. EPA and the State Water Resources Control Board to determine where certain contaminants occur and whether the contaminants need to be regulated.

Definitions

AL (Regulatory Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

LRAA (Locational Running Annual Average): The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters. Amount Detected values for TTHMs and HAAs are reported as the highest LRAAs.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs (SMCLs) are set to protect the odor, taste and appearance of drinking water.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. EPA.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable.

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

NS: No standard

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

PDWS (Primary Drinking Water Standard): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

PHG (Public Health Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California EPA.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

TON (Threshold Odor Number): A measure of odor in water.

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.